



Product Service

# Attestation of Conformity

No. E8A 098238 0049 Rev. 00

**Holder of Attestation:** **HANYOUNG NUX CO., LTD.**  
28, Gilpa-ro 71beon-gil, Michuhol-gu  
Incheon 22121  
REPUBLIC OF KOREA

**Name of Object:** **Control Equipment  
(Analog Twin Timer)**

This Attestation of Conformity is issued on a voluntary basis according to the Directive 2014/30/EU relating to electromagnetic compatibility. It confirms that the listed apparatus complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** UCSCE-2212-0061R1

**Date,** 2023-02-06

( Laurent Yuan )

Page 1 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



TUV®



Product Service

# Attestation of Conformity

No. E8A 098238 0049 Rev. 00

**Model(s):** TF62A-yz-A

**Description of Object:**

Rated input voltage:	24-240 V a.c.
Rated input frequency:	50/60 Hz
Rated input Voltage:	24-240 V d.c.

-Model TF62A-6N-A is worst condition, therefore tested representatively for the below mentioned series models.  
 -Definition of variables:

TF62A-yz-A		
Variable	Range of variable	Content
1st 'y' (Time range)	1,3,6	1: Maximum time : 1 sec / 1 min / 1 hour / 10 sec / 10 min / 10 hour 3: Maximum time : 3 sec / 3 min / 3 hour / 30 sec / 30 min / 30 hour 6: Maximum time : 6 sec / 6 min / 6 hour / 60 sec / 60 min / 60 hour
2nd 'z' (Control output)	N	No option

**Tested according to:**

- EN 61000-6-2:2005
- EN IEC 61000-6-2:2019
- EN 61000-6-4:2007/A1:2011
- EN IEC 61000-6-4:2019
- EN 61000-3-2:2014
- EN IEC 61000-3-2:2019/A1:2021
- EN 61000-3-3:2013
- EN 61000-3-3:2013/A2:2021

Page 2 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

