



Product Service

Attestation of Conformity

No. E8A 098238 0034 Rev. 00

Model(s):

**VX7-UCMA-abcdef, VX7-UMMA-abcdef,
VX7-USMA-abcdef**

Variable	Range of variable	Contents
a	Sub Output	A1: Relay 1 A2: Relay 1 & 2 A3: Relay 1, 2 & 3 A4: Realy 1, 2, 3 & 4
b	Communication	Blank: None C: RS-485
c	Retransmission Output(RET)	Blank: None T: (4-20) mA
d	Digital Input (DI)	Blank: None D2: 2 Points (DI 1 - 2) D4: 4 Point (DI 1 - 4)
e	Current Detection Input (CT)	Blank: None H1: CT 1 H2: CT 1 & 2
f	Remote Input	Blank: None R: (4-20) mA

Description of Objects:

Rated input voltage: 100-240 V a.c.
Rated input frequency: 50/60 Hz

Tested according to:

EN 61000-6-2:2005
EN 61000-6-4:2007/A1:2011
EN 61000-3-2:2014
EN 61000-3-3:2013

Page 2 of 2

After preparation of the necessary technical documentation as well as the EU Declaration of conformity the required CE marking can be affixed on the product. That Declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD
ZERTIFIKAT ◆ CERTIFICATE ◆ 認證書 ◆ CERTIFICADO ◆ CERTIFIKAT ◆



A4 / 07.17