ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT
TÜV SÜD

Product Service

Attestation of Conformity

No. N8A 098238 0035 Rev. 00

Holder of Certificate: **HANYOUNG NUX CO., LTD.**
28, Gilpa-ro 71beon-gil, Nam-gu
Incheon 22121
REPUBLIC OF KOREA

Product: **Switches**
(Pandant Swtich)

Model(s): **HY-P102xy**

Remark:
x: it can be 2, 4, 6, 8, 9 numbers according to Number of switch configurations

y: it can be S, A, B, C, D, E, F, H, K, M, P, Y numbers according to Switch Contact Shape

Parameters:

Rated input voltage:	250 Va.c.
Rated insullation voltage:	250 Va.c.
Rated impulse withstand voltage:	4 kV
Pollution degree:	3
Overvoltage category:	II
Rated input frequency:	50/60 Hz
Degree of protection:	IP65

Tested according to:

EN 60947-1:2007/A2:2014
EN 60947-5-1:2004/A1:2009

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance.
It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: CPSA01223619

Date, 2019-08-22 (Harry Kwon)

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

A4 / 07.17